
THE INFORMATION HEREON IS THE PROPERTY OF SIMPLEX, INC., AND/OR ITS SUBSIDIARIES, WITHOUT WRITTEN PERMISSION ANY COPYING, TRANSMITTAL TO OTHERS AND USE EXCEPT THAT FOR WHICH IT IS LOAMED IS PROHIBITED.

(2016 SIMPLEX, INC. ALL RIGHTS RESERVED

PORT	DESCRIPTION	SIZE
Α	ENGINE SUPPLY DROP TUBE - (QTY. 2) (1.000 CLEARANCE TO BOTTOM)	0.75" NPT, MALE
В	SECONDARY TANK E-VENT PORT	2.00" NPT, FEMALE
С	OVERFLOW PORT	2.00" NPT, FEMALE
D	ENGINE RETURN PORT	1.00" NPT, FEMALE
Ε	EXTRA PIPE FLANGE (QTY. 2)	1.00" NPT, FEMALE
F	TANK VENT PORT	2.00" NPT, FEMALE
G	MANUAL FILL PORT W/ BLEED HOLE (6.000 CLEARANCE TO BOTTOM)	2.00" NPT, MALE
Н	HAND PUMP DROP TUBE (1.000 CLEARANCE TO BOTTOM)	0.75" NPT, MALE
J	PUMP CONNECTION TO TANK (QTY. 3) (1.000 CLEARANCE TO BOTTOM)	0.75" NPT, MALE
Κ	FLOATSWITCH MOUNTING PORT (QTY. 3)	1.00" NPT, FEMALE
L	PRIMARY EMERGENCY VENT PORT	2.00" NPT, FEMALE
М	SECONDARY TANK DRAIN PORT	0.50" NPT, FEMALE
N	PRIMARY TANK DRAIN PORT	0.50" NPT, FEMALE
R	LEAK SENSOR PORT	1.50" NPT, FEMALE

1.50" NPT, FEMALE



NOTES:

1) CONSTRUCTION: 12 GA. H.R.S. TANK TOP: 10 GA. H.R.S.

2) LISTING: UL 142

- 3) RATING: ATMOSPHERIC TANK TESTED TO 3 PSI
- 4) ALL DIMENSIONS ±.125"
- 5) TANK COLOR = SIMPLEX CAROLINA VERMILLION CONTROLLER COLOR = SIMPLEX COASTAL HAZE

SPRINGFIELD, ILLINOIS

REVISED :

STS 60 GALLON


DATE: 04/27/16

FUEL OIL DAY TANK

SIMPLEX TECNOLOGY SERIES

DRAWN BY : AMH

274281A



S EXTRA PORT

